

Energy performance certificate (EPC)

8 Gloucester Court HILLSBOROUGH BT26 6HD	Energy rating E	Valid until: 28 June 2033 <hr/> Certificate number: 2611-3028-7206-0327-1204
--	---------------------------	---

Property type

Detached house

Total floor area

153 square metres

Energy rating and score

This property's current energy rating is E. It has the potential to be D.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		
55-68	D		59 D
39-54	E	44 E	
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D
the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Good
Wall	Timber frame, as built, insulated (assumed)	Good
Roof	Pitched, 350 mm loft insulation	Very good
Roof	Pitched, limited insulation (assumed)	Poor
Roof	Roof room(s), limited insulation (assumed)	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 57% of fixed outlets	Good
Floor	Suspended, no insulation (assumed)	N/A
Floor	To unheated space, no insulation (assumed)	N/A
Secondary heating	Room heaters, LPG	N/A

Primary energy use

The primary energy use for this property per year is 238 kilowatt hours per square metre (kWh/m²).

How this affects your energy bills

An average household would need to spend **£3,285 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £902 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's current environmental impact rating is E. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year. CO₂ harms the environment.

Carbon emissions

An average household produces 6 tonnes of CO₂

This property produces 9.4 tonnes of CO₂

This property's potential production 6.7 tonnes of CO₂

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Low energy lighting	£30	£71
2. Room-in-roof insulation	£1,500 - £2,700	£110
3. Floor insulation (suspended floor)	£800 - £1,200	£398
4. Condensing boiler	£2,200 - £3,000	£323
5. Solar water heating	£4,000 - £6,000	£89
6. Solar photovoltaic panels	£3,500 - £5,500	£630

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	John Mullan
Telephone	07876702698
Email	johnnymullan@hotmail.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/020520
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	29 June 2023
Date of certificate	29 June 2023
Type of assessment	RdSAP
